

# Manual Supplement

Manual Title: 116 Users  
Part Number: 2538688  
Print Date: July 2006  
Revision/Date: 1, 2/07

Supplement Issue: **2**  
Issue Date: 4/13  
Page Count: 2

---

---

This supplement contains information  
necessary to ensure the accuracy of  
the above manual.

## Change #1


On page 2, under **Safety Information**:

Change: **Do not use the Meter around explosive gas or vapor.**

To: **Do not use the Product around explosive gas, vapor, or in damp or wet environments.**

## Change # 2, 63351, 65311

On page 3, add the following to the Symbols table:

	Conforms to relevant South Korean EMC Standards
CAT III	Measurement Category III is applicable to test and measuring circuits connected to the distribution part of the building's low-voltage MAINS installation.

CAT IV	Measurement Category IV is applicable to test and measuring circuits connected at the source of the building's low-voltage MAINS installation.
--------	--

On pages 18 and 19, remove **Surge Protection, Safety Compliance, Certifications** and **IP Rating** and add:

<b>Safety</b> .....	IEC 61010-1: 600 V CAT III, Pollution Degree 2
<b>Electromagnetic Environment</b> .....	IEC 61326-1: Portable
<b>Electromagnetic Compatibility</b> .....	Applies to use in Korea only. Class A Equipment (Industrial Broadcasting & Communication Equipment) <sup>[1]</sup>

[1] This product meets requirements for industrial (Class A) electromagnetic wave equipment and the seller or user should take notice of it. This equipment is intended for use in business environments and is not to be used in homes.