

Rosemount™ 248 HART® Head Mount Configuration Data Sheet

BOLD = Required value

***** = Default

Select only one of the items provided

One or more of the listed items can be selected

| Customer information | |
|---------------------------|-----------------------|
| Customer: _____ | Contact name: _____ |
| Phone no.: _____ | Fax no./email: _____ |
| P.O./reference no.: _____ | P.O. line item: _____ |
| Quote no.: _____ | Model no.: _____ |
| Customer sign-off: _____ | |

| Tagging | |
|--|--|
| Hardware tag: _____ | (13 characters maximum) |
| Software tag: _____ | (8 characters maximum - default is 8 characters of the hardware tag) |
| Long software tag ⁽¹⁾ : _____ | (32 characters maximum) |

1. Requires HR7 option code.

| Sensor configuration | | | |
|---|--|-------------------------------|--------------------------|
| RTDs | Thermocouples | Other sensor types | Measurement range |
| <input type="radio"/> Pt 100* ($\alpha = 0.00385$) IEC | <input type="radio"/> Type B NIST | <input type="radio"/> mV | Upper range value (100%) |
| <input type="radio"/> Pt 200 ($\alpha = 0.00385$) IEC | <input type="radio"/> Type E NIST | <input type="radio"/> ohm | _____ (100 °C*) |
| <input type="radio"/> Pt 500 ($\alpha = 0.00385$) IEC | <input type="radio"/> Type J NIST | Number of leads | Lower range value (0%) |
| <input type="radio"/> Pt 1000 ($\alpha = 0.00385$) IEC | <input type="radio"/> Type K NIST | <input type="radio"/> 2-wire | _____ (0 °C*) |
| <input type="radio"/> Pt 100 ($\alpha = 0.003916$) JIS | <input type="radio"/> Type N NIST | <input type="radio"/> 3-wire | |
| <input type="radio"/> Pt 200 ($\alpha = 0.003916$) JIS ⁽¹⁾ | <input type="radio"/> Type R NIST | <input type="radio"/> 4-wire* | |
| <input type="radio"/> Ni 120 Edison Curve No. 7 | <input type="radio"/> Type S NIST | Units | |
| <input type="radio"/> Cu 10 Edison Copper Winding No. 15 | <input type="radio"/> Type T NIST | <input type="radio"/> mV | |
| <input type="radio"/> Pt 50 ($\alpha = 0.00391$) GOST 6651-94 | <input type="radio"/> Type L DIN | <input type="radio"/> Ohms | |
| <input type="radio"/> Pt 100 ($\alpha = 0.00391$) GOST 6651-94 | <input type="radio"/> Type U DIN | <input type="radio"/> K | |
| <input type="radio"/> Cu 50 ($\alpha = 0.00426$) GOST 6651-94 | <input type="radio"/> Type W5Re/W26Re ASTM | <input type="radio"/> °R | |
| <input type="radio"/> Cu 50 ($\alpha = 0.00428$) GOST 6651-94 | <input type="radio"/> Type L GOST | <input type="radio"/> °C* | |
| <input type="radio"/> Cu 100 ($\alpha = 0.00426$) GOST 6651-94 | | <input type="radio"/> °F | |
| <input type="radio"/> Cu 100 ($\alpha = 0.00428$) GOST 6651-94 | | | |
| <input type="radio"/> Transmitter Sensor Matching ⁽²⁾ | | | |

1. Requires HR7 and C1 option code.

2. Requires the C2 option code.



Options

Custom configuration information below this line requires C1 option code.

| | |
|--|-------------------------|
| Transmitter information | |
| Descriptor: _____ | (16 characters maximum) |
| Message: _____ | (32 characters maximum) |
| Date: _____ (MM/DD/YYYY; default is date of final configuration) | |
| Failure mode switch: <input type="radio"/> High★ <input type="radio"/> Low | |

| | |
|--|----------------------------------|
| Damping | |
| <input type="radio"/> 0 second | <input type="radio"/> 5 seconds★ |
| <input type="radio"/> Other _____ (0.5 to 32 in 0.1 sec. increments) | |

| | |
|--|--|
| Alarm and saturation values | |
| <input type="radio"/> Rosemount standard levels★ | |
| (High alarm = 21.75 mA; Low alarm = 3.75 mA; High saturation = 20.5 mA; Low saturation = 3.9 mA) | |
| <input type="radio"/> NAMUR - compliant (available with option codes A1 or CN) | |
| <input type="radio"/> Custom (option code C1) | |
| High alarm level: _____ | mA (must be between 21.0 and 23.0 mA) |
| Low alarm level: _____ | mA (must be between 3.5 and 3.75 mA) |
| High saturation level: _____ | mA (must be between 20.5 to 20.9 mA) |
| Low saturation level: _____ | mA (must be between the low alarm value plus 0.1 mA, 3.9 mA, and minimum 3.7 mA) |

| | |
|-----------------------------|--|
| Security information | |
| Software write protection: | <input type="radio"/> Enable <input type="radio"/> Disabled★ |

Global Headquarters

Emerson Automation Solutions

6021 Innovation Blvd.
Shakopee, MN 55379, USA
☎ +1 800 999 9307 or +1 952 906 8888
☎ +1 952 949 7001
✉ RFQ.RMD-RCC@Emerson.com

North America Regional Office

Emerson Automation Solutions

8200 Market Blvd.
Chanhassen, MN 55317, USA
☎ +1 800 999 9307 or +1 952 906 8888
☎ +1 952 949 7001
✉ RMT-NA.RCCRFQ@Emerson.com

Latin America Regional Office

Emerson Automation Solutions

1300 Concord Terrace, Suite 400
Sunrise, FL 33323, USA
☎ +1 954 846 5030
☎ +1 954 846 5121
✉ RFQ.RMD-RCC@Emerson.com

Europe Regional Office

Emerson Automation Solutions Europe GmbH

Neuhofstrasse 19a P.O. Box 1046
CH 6340 Baar
Switzerland
☎ +41 (0) 41 768 6111
☎ +41 (0) 41 768 6300
✉ RFQ.RMD-RCC@Emerson.com

Asia Pacific Regional Office

Emerson Automation Solutions

1 Pandan Crescent
Singapore 128461
☎ +65 6777 8211
☎ +65 6777 0947
✉ Enquiries@AP.Emerson.com

Middle East and Africa Regional Office

Emerson Automation Solutions

Emerson FZE P.O. Box 17033
Jebel Ali Free Zone - South 2
Dubai, United Arab Emirates
☎ +971 4 8118100
☎ +971 4 8865465
✉ RFQ.RMTMEA@Emerson.com

Questions? **TRANSCAT**
[Contact Our Rosemount Configuration Specialist](#) Trust in every measure

Emerson Terms and Conditions of Sale are available upon request.
The Emerson logo is a trademark and service mark of Emerson Electric Co. Rosemount is a mark of one of the Emerson family of companies. All other marks are the property of their respective owners.
© 2019 Emerson. All rights reserved.