

Manual Supplement

Manual Title: 114, 115, and 117 Users Supplement Issue: **4**
Part Number: 2538674, 2572573 Issue Date: 11/13
Print Date: July 2006 Page Count: 3
Revision/Date: 1, 2/07

This supplement contains information necessary to ensure the accuracy of the above manual.

Change #1


On page 2, under **Safety Information**:

Change: Do not use the Meter around explosive gas or vapor.

To: Do not use the Product around explosive gas, vapor, or in damp or wet environments.

Change #2, 63151, 63350

On page 3, add the following to the Symbols Table:

	Conforms to relevant South Korean EMC Standards
CAT II	Measurement Category II is applicable to test and measuring circuits connected directly to utilization points (socket outlets and similar points) of the low-voltage MAINS installation.
CAT III	Measurement Category III is applicable to test and measuring circuits connected to the distribution part of the building's low-voltage MAINS installation.

CAT IV	Measurement Category IV is applicable to test and measuring circuits connected at the source of the building's low-voltage MAINS installation.
--------	--

On pages 19 & 20, under **General Specifications**, delete **Surge Protection, Safety Compliance and Certifications** and add:

SafetyIEC 61010-1: 600 V CAT III, Pollution Degree 2

Electromagnetic EnvironmentIEC 61326-1: Portable

Electromagnetic CompatibilityApplies to use in Korea only:

Class A Equipment (Industrial Broadcasting & Communication Equipment) ^[1]

[1] This product meets requirements for industrial (Class A) electromagnetic wave equipment and the seller or user should take notice of it. This equipment is intended for use in business environments and is not to be used in homes.

Change #3, 66502

On page 22, add 99.99 kHz to the **Range** and 0.01 kHz to the **Resolution** of the Hz function column and replace Note 2 with:

- [2] AC Volts Hz is ac-coupled and specified from 5 Hz to 99.99 kHz. Minimum input required above 50.00 kHz typically is > 1.1 vac sine. Minimum input typical and not specified. AC Amps Hz is dc-coupled and specified from 45 Hz to 5 kHz.