


Manual Supplement

Manual Title:	1587/1577 Warranty & Safety Information Supplement Issue: 2		
Part Number:	2406034	Issue Date:	5/13
Print Date:	April 2005	Page Count:	1
Revision/Date:			

This supplement contains information necessary to ensure the accuracy of the above manual.

Change #1

Under the **Symbols** table add:

	Conforms to relevant South Korean EMC Standards.
CAT II	Measurement Category II is applicable to test and measuring circuits connected directly to utilization points (socket outlets and similar points) of the low-voltage MAINS installation.
CAT III	Measurement Category III is applicable to test and measuring circuits connected to the distribution part of the building's low-voltage MAINS installation.
CAT IV	Measurement Category IV is applicable to test and measuring circuits connected at the source of the building's low-voltage MAINS installation.